

HIGH FIRE HAZARD EVALUATION

INSPECTOR (FIRST, M.I., LAST)	INSPECTOR'S TITLE	STATION	SHIFT	EVALUATION DATE
-------------------------------	-------------------	---------	-------	-----------------

IF YOU HAVE QUESTIONS CONCERNING THIS EVALUATION NOTICE, CALL:

INSPECTEE	NAME (LAST, FIRST)			
	ADDRESS			
	CITY		STATE	ZIP
	11. PHONE NUMBER #1		12. PHONE NUMBER #2	13. E-MAIL ADDRESS

14. <input type="checkbox"/> No violations observed. (check if applicable)	15. VIOLATION RE EVALUATION? <input type="checkbox"/> YES <input type="checkbox"/> NO	16. EVALUATION # <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3	17. FOLLOW-UP EVALUATION DATE: <input type="checkbox"/> N/A
---	--	--	--

Items in red are required annually under Santa Barbara Municipal Code 8.04

ACCESS

YES	NO		Recommendations:
<input type="checkbox"/>	<input type="checkbox"/>	Home address visible from the street	
<input type="checkbox"/>	<input type="checkbox"/>	Home address made of fire resistive materials	
<input type="checkbox"/>	<input type="checkbox"/>	Directional signs as needed	
<input type="checkbox"/>	<input type="checkbox"/>	Are directional/street signs made of fire resistant materials	
<input type="checkbox"/>	<input type="checkbox"/>	If driveway is long, does it have suitable turnaround area	
<input type="checkbox"/>	<input type="checkbox"/>	Gates and locks operable by fire agencies	
<input type="checkbox"/>	<input type="checkbox"/>	Vegetation cleared both horizontally 10' and vertically 13'6" from roadways on or bordering your property	
<input type="checkbox"/>	<input type="checkbox"/>	Dry grasses cut to 2 inches	

STRUCTURE

YES	NO		Recommendations:
<input type="checkbox"/>	<input type="checkbox"/>	Class A roof	
<input type="checkbox"/>	<input type="checkbox"/>	Tile stoppers at ends	
<input type="checkbox"/>	<input type="checkbox"/>	Spark arrestors and 1/4" mesh on chimney	
<input type="checkbox"/>	<input type="checkbox"/>	Boxed eaves and enclosed decks	
<input type="checkbox"/>	<input type="checkbox"/>	All exterior vents (attic, eave, etc.) comply with current OSFM standards	
<input type="checkbox"/>	<input type="checkbox"/>	Windows dual paned with 1 pane tempered	
<input type="checkbox"/>	<input type="checkbox"/>	Structure has noncombustible siding	
<input type="checkbox"/>	<input type="checkbox"/>	Decks and porches made of non-combustible material and free of easily combustible material (i.e. plastic furniture, seat cushions, shade umbrellas)	
<input type="checkbox"/>	<input type="checkbox"/>	Remove wood piles and other combustibles at least 30' from house	
<input type="checkbox"/>	<input type="checkbox"/>	Resident has smoke detectors, fire extinguishers & evacuation plan	
<input type="checkbox"/>	<input type="checkbox"/>	Residential sprinklers in operating condition	
<input type="checkbox"/>	<input type="checkbox"/>	Rain gutters and roof free of leaves, needles and branches	
<input type="checkbox"/>	<input type="checkbox"/>	Trees limbed minimum 10ft from chimney	

DEFENSIBLE SPACE

YES	NO		Recommendations:
<input type="checkbox"/>	<input type="checkbox"/>	All flammable brush is lean, clean and green (limbed, pruned and maintained) within designated defensible space zone (30-50-70-100-150ft)	
<input type="checkbox"/>	<input type="checkbox"/>	All fire ladders removed	
<input type="checkbox"/>	<input type="checkbox"/>	Dry grass cut to 2 inches	
<input type="checkbox"/>	<input type="checkbox"/>	Shrubs trimmed up 2ft or 1/3 of height, all dead removed	
<input type="checkbox"/>	<input type="checkbox"/>	Shrubs and clusters spaced 18' apart	
<input type="checkbox"/>	<input type="checkbox"/>	All dead wood removed and trees limbed up 6ft above ground or as much as possible with younger trees.	
<input type="checkbox"/>	<input type="checkbox"/>	Trees limbed a minimum 10ft from eaves and roofline	
<input type="checkbox"/>	<input type="checkbox"/>	All dead trees removed from property	
<input type="checkbox"/>	<input type="checkbox"/>	Separation between trees and crowns	
<input type="checkbox"/>	<input type="checkbox"/>	LPG tank clear of combustible material 10ft in all directions	

--	--